

# CIRLOCK

CIRLOCK – LOCKOUT / TAGOUT EQUIPMENT

## ALL PLASTIC Cable Lockout Device

**MFL-2P**

**Instructions**

---

**Warning:** Always perform a De-Energization Test both before and after using this product. Always perform a Blocking Verification Test after using this product.

De-Energization Test: All associated isolation devices, such as switches, valves etc., should be verified as de-energized prior to and following the use of this CIRLOCK device.

Blocking Verification Test: If this lockout device can not be installed in a manner that will hold the appropriate energy isolating devices in a safe or off position, the device shall NOT be used.

### Application:

**MFL-2P has no external metal parts, for good isolation, and its plastic cable is recommended for light duty use only. Cable is easily cut.**

Thread cable end through devices to be locked, i.e.: Circuit Breakers or Fuse Holder lockout devices. Then thread end of cable through lockout device MFL-2P, continue till cable is tight, close the lockout device, and place up to 4 padlocks and tags as needed.



**Disclaimer:** Appropriate use of this product is the sole responsibility of the user in relation to health and safety regulations. Before using, user shall determine the suitability of the product for his intended use and user assumes all risk and liability whatsoever in connection therewith.

Erik Larsen Pty. Ltd. t/as CIRLOCK is not responsible for any loss or damage arising from the use of this product, which is beyond Erik Larsen P/L control, and liability is restricted to the replacement of material proven faulty.

Made by or for:

**CIRLOCK**

Ph: +61-(0)7-54452910    [www.cirlock.com.au](http://www.cirlock.com.au)