

CIRLOCK

CIRLOCK – LOCKOUT / TAGOUT EQUIPMENT

SALD – Type Lockout Device for Individual Mounted C/B's

SALD-

Instructions

Warning: Always perform a De-Energization Test both before and after using this product. Always perform a Blocking Verification Test after using this product.

De-Energization Test: All associated isolation devices, such as switches, valves etc., should be verified as de-energized prior to and following the use of this CIRLOCK device.

Blocking Verification Test: If this lockout device can not be installed in a manner that will hold the appropriate energy isolating devices in a safe or off position, the device shall NOT be used.

APPLICATION:

1. CIRLOCK SALD- Types lockout devices are to be permanently attached to the C/B's escutcheon plate, with screws and rivets. Different variations are to be used for different types of C/B's. Installer/user must ensure use of correct type. See catalogue for details.
2. With the C/B in 'OFF' position, install the SALD- lockout device as shown, using supplied spacers where needed.
3. Insert a padlock with minimum 5mm shackle through both holes. Verify C/B can not be repositioned to the 'ON' position.

If the device can not securely lock out the C/B – **IT SHALL NOT BE USED.**



Disclaimer: Appropriate use of this product is the sole responsibility of the user in relation to health and safety regulations. Before using, user shall determine the suitability of the product for his intended use and user assumes all risk and liability whatsoever in connection therewith.

Erik Larsen Pty. Ltd. t/as CIRLOCK is not responsible for any loss or damage arising from the use of this product, which is beyond Erik Larsen P/L control, and liability is restricted to the replacement of material proven faulty.

Made by or for:

CIRLOCK

Ph: +61-(0)7-54452910 www.cirlock.com.au